



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2026 T/J(246/2026)

31 August 2026

Vola A/S
Local Correspondence Address:
16th Floor, First Commercial Building,
33 Leighton Road, Causeway Bay,
Hong Kong

Dear Sir/Madam,

**Approval of "VOLA" Basin Mixer
(General Acceptance No. ZC20260615)**

Your E-Application [file-id: ETJ-GA-20260323-130] dated 23 March 2026 and subsequent submissions received by this department up to 4 August 2026 refer.

Having considered the test report ref. J30934A issued on 12 February 2026 by Nutek Systems (HK) Limited and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Vola A/S
Country of Origin: Denmark
Brand: Vola
Details of Fitting: 3/8" Single lever basin mixer with 2 nos. of flexible hose approved by UK's WRAS under ref. 250702033
Model: 590H
Body Markings: vola
Expiry Date: 30 August 2031

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."


A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,


(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only